

Development of a Package of Energy-Saving Measures and a Technical and Economic Assessment of Their Effectiveness

Islom Khafizov¹, Samad Nimatov^{2,a)}, Xudoyor Hafizov¹, Odiljon Zaripov^{2,3},
Mukhiddin Atajonov⁴, Davronbek Abdullaev⁵, Sevinch Olimjonova⁶

¹ Bukhara State Technical University, Bukhara, Uzbekistan

² Tashkent State Technical University named after Islam Karimov, Tashkent, Uzbekistan

³ Almalyk State Technical Institute, Almalyk, Uzbekistan

⁴ Andijan State Technical Institute, Andijan, Uzbekistan

⁵ European Multidisciplinary University (EMU), Tashkent, Uzbekistan

⁶ National University of Uzbekistan named after Mirzo Ulugbek, Tashkent, Uzbekistan

^{a)} Corresponding author: Nimatov@mail.ru

Abstract. This article presents the results of an energy audit of heating systems in Uzbekistan. A list of measures was developed to reduce fuel and energy consumption and improve the overall efficiency of equipment operation. The article examines actual measurement data, the results of energy balance analysis, and identified technical and organizational shortcomings in equipment operation.

INTRODUCTION

In the context of implementing state policy on energy conservation and improving energy efficiency in the Republic of Uzbekistan, particular attention is paid to heating systems as major consumers of fuel and energy resources. An energy audit is our primary tool for comprehensively assessing the current state of energy consumption, identifying losses, and determining ways to improve resource efficiency [1-4]. Given rising energy tariffs, the need to reduce the carbon footprint, and the importance of enhancing the competitiveness of utility infrastructure, the rational use of energy is becoming particularly significant. Central heating plants within heating systems are among the largest consumers in urban areas, and their efficiency directly impacts the overall energy expenditure at the scale of a metropolis [5-9]. Over the last decade, electricity generation from wind farms has gained enormous importance worldwide and has reached a point where it has a significant impact on the energy supply in many countries, both in terms of installed capacity and in terms of the annual share of energy produced. Thus, installed capacity (Fig.1) has increased by approximately 100-200% since 2010. According to statistics, 20-30% of consumed energy can be lost due to equipment wear and tear, lack of automation, insufficient thermal insulation, suboptimal boiler operating modes, and improper operation of water treatment and circulation systems. The following methods are employed [10-14]:

- Direct measurement (where metering devices are installed);
- Calculated equivalents (where data is unavailable - standards and specifications are used);
- Energy coefficients (efficiency, loss coefficients, specific consumption rates);
- Comparative analysis with data from previous years and industry standards.

1. Calculation of Input Energy. The energy input from fuel is calculated using the following formula:

$$Q_{in} = VU_{lh} \quad (1)$$

Where, Q_{in} - Thermal energy supplied with the fuel, kWh ; V - Volume of fuel consumed, m^3 (for natural gas); U_{lh} - Lower heating value of the fuel, kWh/m^3 .

2. Calculation of Useful Energy. The heat produced (hot water) is determined by the following formula:

$$Q_{useful} = Gc(T_{out} - T_{in}) \quad (2)$$

Where, Q_{useful} - Useful heat, kWh; G - Flow rate of the heat transfer medium, t/h; c - Specific heat capacity; T_{out} , T_{in} - Outlet and inlet temperatures.

3. Loss Calculation. Heat losses through flue gases are calculated using the following formula:

$$Q_{loss} = Q_{in} - Q_{useful} \quad (3)$$

The following are also considered:

- Radiation and convection losses (thermographic measurements);
- Heat transfer fluid leaks;
- Idle operation;
- Underloading of equipment.

4. Calculation of Boiler and Unit Efficiency. Actual efficiency (η) is calculated using the following formula:

$$\eta = \frac{Q_{useful}}{Q_{in}} \cdot 100\% \quad (4)$$

Balancing Data by Facility. All data for each boiler and boiler house is summarized in tables. The following graphs are also created:

- Sankey diagrams;
- Pie charts of proportions;
- Bar charts of specific consumption.

Units of Measurement and Conversion to Fuel Equivalent. For ease of analysis and comparison, all energy parameters are converted to consistent units:

- Thermal energy - in Gcal or kWh;
- Gas - in m³, then in kWh or in tonnes of conventional fuel (tce) (Table 1);
- Electricity - in kWh.

Everything is converted to tce using the following coefficients:

TABLE 1. Conversion of Units of Measurement to tce

Energy Resource	tce Coefficient
1000 m ³ Natural Gas	1.16 tce
1000 kWh Electricity	0.123 tce
Gcal Heat	0.143 tce

EXPERIMENTAL RESEARCH

Measurement Methods and Equipment Used. To ensure objective and reliable energy audits, measurements were taken in accordance with ISO 50002:2014, GOST 32144-2013, and other Uzbek standards [15-19].

Measurements included [20-24]:

- Fuel consumption;
- Temperatures of heat transfer fluid, air, and structures;
- Flue gas composition;
- Electrical parameters (voltage, current, power factor);
- Power quality (THD, harmonics);
- Ventilation and water supply parameters;
- Building and pipeline heat losses.

Main Types of Measurements [25-29].

1. Temperature Measurements – of water, steam, gas, air, return flow, and equipment;
2. Flue Gas Analysis – measuring O₂, CO, CO₂, calculating efficiency, and determining excess air;
3. Vacuum and Pressure Measurements – in the furnace, stack, and under burners;
4. Water and Gas Flow Measurements – using meters and an ultrasonic flowmeter;
5. Thermographic Inspection – to identify heat loss;
6. Electrical Measurements – current, voltage, active/reactive power, power factor;
7. Power Quality Analysis:
 - Phase voltages and currents;
 - THD (Total Harmonic Distortion);
 - Harmonics up to the 50th order;
 - Power factor and phase unbalance;

- Voltage dips and surges;
- Total, active, and reactive power.

Applied Formulas:

1. Boiler Efficiency (from Flue Gas Analysis):

$$\eta = 100 - q_2 - q_4 - q_5 - q_6 \quad (5)$$

where: q_2 - losses with exhaust gases, q_4 - losses from incomplete combustion, q_5 - mechanical incomplete combustion, q_6 - losses from radiation and convection.

2. Heat Losses from Thermography:

$$Q = \lambda \cdot \frac{T_{surf} - T_{air}}{\delta} \cdot A \cdot t \quad (6)$$

where: λ - thermal conductivity (W/m⁰C); T_{surf} - surface temperature; T_{air} - ambient temperature; δ - wall thickness; A - area; t - time.

3. Water Mass Flow Rate:

$$G = \rho \cdot A \cdot v \quad (7)$$

where: G - mass flow rate (kg/s); ρ - density (kg/m³); A - pipe cross-sectional area (m²); v - flow velocity (m/s).

A list of buildings and premises was compiled to conduct the instrumental survey, and Table 2 provides information on the purpose of the buildings, their total area, and their letter designations according to the enterprise's technical passport. This data is used for further calculations of thermal energy consumption and for the assessment of energy efficiency [30-36].

TABLE 2. List of Buildings and Premises

№	Building name	Area (m ²)	Code
1	Production Workshop №1	7316	0001 A
2	Gatehouse	49	0005 B
3	Boiler House	701	0021 C
4	Warehouse	74	0006 D
5	Fuel Oil Preparation Building	480	0008 E

The total area of buildings and structures is 8,620 m², and the composition and distribution of building areas are considered when analyzing thermal loads, calculating the heat energy requirement for heating, and developing recommendations for energy efficiency [37-41].

As part of the energy audit conducted at the combined heat and power plant in July 2025, instrumental measurements were taken of boiler unit №1, a PTVM-50 type (manufactured in 1979). The boiler operates on natural gas and is equipped with 12 gas burners, each with a nominal capacity of 600 m³/h. Air is supplied by V-Ts14-46 №4 fans, with a total of 12 units per boiler, each with a nominal capacity of approximately 7000 m³/h.

During the instrumental survey of boiler unit №1, electrical parameters of the feed motors for the forced draft fans were measured. Phase currents, supply voltage, and power factor ($\cos\phi$) were measured, and used to calculate the actual power consumption of each fan. The obtained values were compared with the rated power of the electric motors, allowing for an assessment of the equipment load and identification of potential deviations from normal operating conditions [42-45].

The measurements revealed that the forced draft fans of boiler unit №1 are operating within normal parameters, with motor loading ranging from 59% to 91% of their rated power. This indicates that some motors are operating with a power reserve, which positively impacts equipment lifespan by reducing the risk of overheating and premature wear. The total electrical power consumption of the fans was 15.9 kW, which aligns with calculated values for this type of equipment. No overloads or abnormal deviations were detected in the operation of the electric motors, and the system is functioning stably [46-49].

To improve energy efficiency, it is recommended to consider implementing variable frequency drives (VFDs). This would allow for flexible adjustment of fan performance based on current demand and reduce excessive energy consumption [50-51].

Parameters recorded during measurements:

Boiler №1:

- Water flow through the boiler: 850 t/h;
- Water temperature before the boiler: 38.2⁰C;
- Water temperature after the boiler: 61.9⁰C;
- Gas flow: 2780 m³/h at a pressure of 0.22 kgf/cm²;

- Water pressure: inlet: 14.2 kgf/cm², outlet: 10.8 kgf/cm².

Based on instrumental measurements, the boiler's useful thermal output was calculated. Gas consumption during the survey period was 2,780 m³/h, taking into account the net heating value of natural gas, equal to 8,114 kcal/m³.

Therefore, the fuel heat input to the boiler furnace was determined to be:

$$Q_{fuel} = V_{gas} \cdot q_{nr} = 2780 \cdot 8,114 = 22,55 \text{ Gcal/h} \quad (8)$$

The boiler's useful thermal output was calculated based on water flow rate and its inlet and outlet temperatures. With a feed rate of 840 t/h, heated from 61°C to 74.4°C, the heating output was:

$$Q_{floor} = G \cdot c \cdot \Delta T = 850 \cdot 1 \cdot (61.9 - 38.2) = 20,15 \text{ Gcal/h} \quad (9)$$

Where: G is the water flow rate, t/h; c is the specific heat capacity of water, assumed to be 1 kcal/kg·°C; ΔT is the difference in water temperature at the boiler inlet and outlet.

The boiler efficiency (COP) is defined as the ratio of the useful thermal power to the fuel heat input:

$$Q = \frac{Q_{floor}}{Q_{fuel}} \cdot 100\% = \frac{20.15}{22.52} \cdot 100\% = 89\% \quad (10)$$

RESEARCH RESULTS

Thermal imaging surveys of the boiler surfaces revealed that the temperature of the outer walls in various areas ranged from 47°C to 102°C. The average values ranged from 65-75°C; however, localized overheating points reaching 100-102°C were observed, indicating significant heat loss through the insulation layer [52-55].

Particularly high temperatures were observed at joints and connections, where the thermal insulation had partially lost its properties. The temperature difference between the coldest and hottest spots reached 50°C, indicating unevenness of the thermal insulation coating. Thermogram data confirm that the current thermal insulation thickness is insufficient. To reduce heat loss and bring boiler operation into compliance with energy efficiency requirements, it is recommended to increase the thermal insulation layer on the boiler surface by 5-10 cm and perform localized restoration of the insulation coating in areas with maximum losses [56-60].

Implementing these measures will reduce heat loss to the environment, decrease specific fuel consumption, and improve the overall efficiency of the boiler units.

As part of the energy audit, instrumental measurements of the pump operating parameters were taken, including power consumption, pressure, flow rate, and water temperature. Additionally, a thermal imaging inspection of the electric motors and pump housings was performed to identify localized overheating and assess the condition of the insulation [61-65].

Particular attention was paid to the electric motor load factor, the operating efficiency of the pump units in various modes, and the presence or absence of automatic control systems (frequency converters, pressure regulators). The results obtained allow us to assess the compliance of actual parameters with rated specifications and identify areas for improving energy efficiency.

As part of the energy audit at TC-3, instrumental measurements and an analysis of the network pumps were conducted. Pumping equipment is one of the main consumers of electrical energy and directly impacts the reliability and efficiency of heat supply. The survey assessed the actual electrical parameters of the operating pump, its compliance with rated specifications, and the level of electric motor load (Table 3) [66-69].

TABLE3. Specifications of the SN-1 network pump

Pump brand	Flow rate, m ³ /h	Head, mwc	Motorpower, kW	Voltage, V	Speed, rpm
CT 1000-180x2	1000	180	630	6000	1500

TABLE 4. Calculated pump operating parameters during inspection

Flow rate, m ³ /h	Head, m	Motor efficiency	cosφ	Load, %	Current, A
1090	180	0,90	0,85	94	67

Analysis revealed that during the inspection of the SN-1 network pump, the actual water flow rate was 1,090 m³/h at a head of 180 m. The 630 kW electric motor operated at approximately 90% load, with a power factor ($\cos\phi$) of 0.85. The calculated current consumption was 64 A, which is below the nominal value (71.2 A), confirming the absence of overload. Overall, the pump's operation complies with technical requirements; however, the high load level requires systematic monitoring and regular control to prevent overloads [70-72].

As part of the instrumental inspection of the TC-3 pumping equipment, thermal imaging measurements of the electric motors of the network pumps were conducted. Thermal imaging was performed under normal operating conditions while the pumps were operating at full load. The purpose of the inspection was to assess the thermal state of the electric motors, identify localized overheating, and determine whether the actual temperature conditions comply with regulatory requirements [73-74].

CONCLUSION

With an annual operating time of 4,320 hours for boiler #4 and an actual hourly fuel consumption range of 3,400-5,000 m³, the estimated savings at 0.5% range from 73,400 m³/year to 108,000 m³/year. The average fuel savings are estimated at approximately 90,700 m³/year.

With each boiler operating for 4,320 hours annually and an hourly natural gas consumption range of 3,400-5,000 m³, the estimated fuel savings from a 2% efficiency increase for one boiler range from 293,800 m³/year to 432,000 m³/year, and for two boilers combined, from 587,500 m³/year to 864,000 m³/year. The average expected savings are estimated at approximately 726,000 m³ of natural gas per year.

Adjusting the burner units of PTVM-50 boilers №1 and №2 to achieve the excess air coefficient ($\lambda=1.2-1.3$) reduces heat loss with exhaust gases and lowers specific fuel consumption. With each boiler operating for 4,320 hours annually and an actual hourly natural gas consumption range of 1,500-3,000 m³, the estimated savings from implementing this measure for one boiler range from 32,400 m³/year to 64,800 m³/year. When calculated for two boilers, the expected effect ranges from 64,800 m³/year to 129,600 m³/year, which equates to approximately 97,200 m³ of natural gas per year.

Restoring and increasing the thermal insulation layer on TC-3 boilers with localized surface overheating of up to 100-102°C will reduce heat loss and reduce excess fuel consumption. With actual annual natural gas consumption in 2024 at 94,168.9 thousand m³, the estimated savings potential from implementing this measure is approximately 470.8 thousand m³ of natural gas per year, confirming its technical feasibility and effectiveness.

Installing variable frequency drives (VFDs) on the blower fans of PTVM-100 boilers №4 and №5 will optimize the operation of the fan equipment and reduce excess energy consumption under variable loads. With each boiler operating for 4,320 hours per year, with four to eight blower fans per unit, and an installed fan capacity of 5.5-11 kW, the estimated annual energy savings for the two boilers total between 19,000 and 76,000 kWh, or approximately 47,500 kWh per year. Implementation of this measure is technically feasible and ensures a sustainable reduction in operating energy costs.

Scheduled maintenance of blower fans, including bearing inspection and replacement, lubricant renewal, and cooling system maintenance, reduces mechanical losses and increases equipment reliability. The estimated savings from implementing this measure are approximately 14,700 kWh per year, confirming the technical feasibility and effectiveness of this solution.

Restoring locally damaged sections of pipeline and heat exchanger insulation reduces surface heat loss and ensures a stable thermal regime. With an annual thermal energy production of 669,407 Gcal and an assumed savings potential of 2%, the estimated savings are approximately 13,388 Gcal per year, equivalent to approximately 1,650,000 m³ of natural gas.

A major overhaul of Storage Tank №2, including restoration of the protective coating and thermal insulation, will reduce surface heat loss and improve thermal energy storage efficiency. With an annual heat output of 393,839 Gcal and a 0.5% loss reduction potential, the estimated savings are approximately 1,969 Gcal per year, equivalent to approximately 243,000 m³ of natural gas per year.

Replacement and restoration of damaged thermal insulation on the pipelines will reduce surface heat loss and improve the energy efficiency of the equipment. With an annual heat output of 393,839 Gcal and a 1% loss reduction potential, the estimated savings are approximately 3,938 Gcal per year, equivalent to approximately 485,000 m³ of natural gas per year. This project is technically and economically feasible and will significantly reduce fuel costs.

Carrying out a major overhaul of the KVGM-180 №1 boiler with the restoration of thermal characteristics and the elimination of operational defects will increase the unit's efficiency and reduce specific fuel consumption. With an hourly natural gas consumption of 5,000-8,000 m³/h and an annual operating time of 4,320 hours, the actual annual consumption ranges from 21.6 million to 34.6 million m³/year. With an increase in efficiency by 2%, the estimated fuel savings will range from 432.0 thousand m³/year to 691.2 thousand m³/year. The average expected effect is estimated at approximately 568.3 thousand m³ of natural gas per year, which confirms the technical and

economic efficiency of this implementation.

REFERENCES

1. I.I.Khafizov. *Development of a system of automatic change of working modes of group control stations*. Web of Semantics: Journal of Interdisciplinary Science, **3**(2), 29, (2025). ISSN: 2960-9550.
2. I.I.Khafizov. *Calculation of transient processes during the start-up of an electric drive with an asynchronous motor connected directly to the network*. Journal of Applied Science and Social Science, **15**(9), (2025).
3. I.I.Khafizov. *Advancements and practical deployment of frequency-controlled drives in pumping infrastructure*. Journal of Applied Science and Social Science, **15**(10), (2025).
4. I.I.Khafizov. *Methods for automatically changing the operating modes of group control centers*. Journal of Multidisciplinary Sciences and Innovations, **4**(10), (2025).
5. I.I.Khafizov. *Mathematical modeling of ion implantation processes into a GaAs(001) single crystal to increase the efficiency of solar cells*. Journal of Multidisciplinary Sciences and Innovations, **4**(11), (2025). ISSN: 2751-4390.
6. X.I.Hafizov, and S.J.Nimatov. *Fundamentals of developing an intellectual model for controlling electricity consumption in the energy system*. In Proceedings of the Republican Scientific and Practical Conference “Problems of Energy and Energy Saving”, (2025).
7. X.I.Hafizov, and S.J.Nimatov. *Integration of renewable energy into microgrids and smart grids in unregulated energy systems*. In Proceedings of the International Scientific and Technical Conference on Improving the Energy Efficiency of the Regional Power Supply System of the Fergana Region, (2025).
8. X.I.Hafizov, and S.J.Nimatov. *Energy management strategy in a smart grid: System view and optimization path*. Problems of Energy and Resource Conservation, Special Issue №88, pp.299-308, (2025).
9. I.E.Mugutskiy, S.J.Nimatov, and X.I.Hafizov. *Fault detection in electrical installations by unmanned aerial systems using multimodal data*. Alternative Energy, **3**(19), (2025).
10. M.Sadullaev, E.Usmanov, R.Karimov, D.Xushvaktov, D.Xalmanov, Y.Shoyimov, D.Khimmataliev. *Mathematical Models and Calculation of Elements of Developed Schemes of Contactless Devices*. AIP Conference Proceedings, 3331(1), **040043**, (2025), <https://doi.org/10.1063/5.0305748>
11. E.Yuldashev, M.Yuldasheva, A.Togayev, J.Abdullayev, R.Karimov. *Energy efficiency research of conveyor transport*. AIP Conference Proceedings, 3331(1), **040030**, (2025), <https://doi.org/10.1063/5.0305742>
12. A.Nuraliyev, I.Jalolov, M.Peysenov, A.Adxamov, S.Rismukhamedov, R.Karimov. *Improving and Increasing the Efficiency of the Industrial Gas Waste Cleaning Electrical Filter Device*. AIP Conference Proceedings, 3331(1), **040040**, (2025), <https://doi.org/10.1063/5.0305751>
13. M.Sadullaev, E.Usmanov, R.Karimov, D.Xushvaktov, N.Tairova, A.Yusubaliev. *Development of Contactless Device Schemes for Automatic Control of the Power of a Capacitor Battery*. AIP Conference Proceedings, 3331(1), **040042**, (2025), <https://doi.org/10.1063/5.0305879>
14. M.Sadullaev, E.Usmanov, R.Karimov, D.Xushvaktov, N.Tairova, A.Yusubaliev. *Review of Literature Sources and Internet Materials on Contactless Devices for Reactive Power Compensation*. AIP Conference Proceedings, 3331(1), **040041**, (2025), <https://doi.org/10.1063/5.0305878>
15. M.Sadullaev, M.Bobojanov, R.Karimov, D.Xushvaktov, Y.Shoyimov, H.Achilov. *Experimental Studies of Contactless Devices for Controlling the Power of Capacitor Batteries*. AIP Conference Proceedings, 3331(1), **040044**, (2025), <https://doi.org/10.1063/5.0307195>
16. E.Usmanov, M.Bobojanov, R.Karimov, D.Xalmanov, N.Tairova, S.Torayev. *Contactless Switching Devices Using Nonlinear Circuits*. AIP Conference Proceedings, 3331(1), **040031**, (2025), <https://doi.org/10.1063/5.0305744>
17. K.Abidov, A.Alimov, M.Gafurova. *Transients in Devices of Control Systems With Excitation Winding*. AIP Conference Proceedings, 3331(1), **040033**, (2025), <https://doi.org/10.1063/5.0305756>
18. O.Ishnazarov, N.Khamudkhanova, K.Kholbutayeva, K.Abidov. *Energy Efficiency Optimization in Irrigation Pump Installations*. AIP Conference Proceedings, 3331(1), **040036**, (2025), <https://doi.org/10.1063/5.0305844>
19. A.Alimov, K.Abidov, E.Abduraimov, F.Akbarov, H.Muminov. *Generalized Model of Nonlinear Inductance and its*. AIP Conference Parameters, 3331(1), **040035**, (2025), <https://doi.org/10.1063/5.0305883>
20. K.Abidov, A.Alimov, N.Khamudkhanova, M.Gafurova. *Determination of the Permissible Number of Pumping Units Supplied From the Transformer of the Amu-Zang-I Substation, Selection of the Power of Static Capacitors*. AIP Conference Proceedings, 3331(1), **040029**, (2025), <https://doi.org/10.1063/5.0305754>

21. F.Akbarov, R.Kabulov, A.Alimov, E.Abduraimov, D.Nasirova. *Dependence of Output Parameters of Photovoltaic Module Based on CIGS Solar Cells on External Temperatures*. AIP Conference Parameters, 3331(1), **040046**, (2025), <https://doi.org/10.1063/5.0305885>
22. K.Abidov, E.Abduraimov, M.Gafurova. *Possibility of Applying Methods of Analysis and Synthesis of Linear Electrical Circuits to Some Nonlinear Circuits*. AIP Conference Proceedings, 3331(1), **040034**, (2025), <https://doi.org/10.1063/5.0305757>
23. E.Abduraimov, M.Peysenov, N.Tairova. *Development of Contactless Device for Maintaining the Rated Voltage of Power Supply Systems*. AIP Conference Proceedings, 2552, **040012**, (2022). <https://doi.org/10.1063/5.0116235>
24. E.Abduraimov. *Automatic control of reactive power compensation using a solid state voltage relays*. Journal of Physics Conference Series, 2373(7), **072009**, (2022). [DOI 10.1088/1742-6596/2373/7/072009](https://doi.org/10.1088/1742-6596/2373/7/072009)
25. E.Abduraimov, D.Khalmanov. *Invention of a contactless voltage relay with an adjustable reset ratio*. Journal of Physics Conference Series, 2373(7), **072010**, (2022). [DOI 10.1088/1742-6596/2373/7/072010](https://doi.org/10.1088/1742-6596/2373/7/072010)
26. E.Abduraimov, D.Khalmanov, B.Nurmatov, M.Peysenov, N.Toirova. *Analysis of dynamic circuits of contactless switching devices*. Journal of Physics Conference Series, 2094(2), **022072**, (2021). [DOI 10.1088/1742-6596/2094/2/022072](https://doi.org/10.1088/1742-6596/2094/2/022072)
27. Y.Adilov, M.Nuraliyev, M.Abdullayev, S.Matkarimov. *Dynamic Performance Model of a Hybrid Power System*. AIP Conference Proceedings, 3331(1), **040038**, (2025). <https://doi.org/10.1063/5.0305909>
28. Y.Adilov, M.Khabibullaev. *Application of fiber-optic measuring current transformer in control and relay protection systems of belt conveyor drives*. IOP Conference Series Earth and Environmental Science, 614(1), **012022**, (2020), [doi:10.1088/1755-1315/614/1/012022](https://doi.org/10.1088/1755-1315/614/1/012022)
29. R.Yusupaliyev, N.Musashayxova, A.Kuchkarov. *Methods of Purification of Polluted Water from Ammonia Compounds at Nitrogen Fertilizer Plants*. E3S Web of Conferences, 563, **03085**, (2024). <https://doi.org/10.1051/e3sconf/202456303085>
30. R.Yusupaliyev, N.Kurbanova, M.Azimova, N.Musashaikhova, A.Kuchkarov. *Establishing a Water-chemical Regime and Increasing the Efficiency of Combustion of a Mixture of Fuel Oil and Gas in a DE 25-14 GM Boiler: A Case Study of the Kokand Distillery*. AIP Conference Proceedings, 2552, **030026**, (2022), <https://doi.org/10.1063/5.0130471>
31. R.Yusupaliyev, B.Yunusov, M.Azimova. *The composition of natural waters of some source rivers of the republic of Uzbekistan, used in the thermal power engineering and the results of the experimental researches at preliminary and ion exchange treatment of water*. E3S Web of Conferences, 139, **01083**, (2019), <https://doi.org/10.1051/e3sconf/201913901083>
32. M.Azimova, N.Kurbanova, D.Rakhmatov. *Large-scale environmental benefits of biogas technology*. AIP Conference Proceedings, 3152(1), **060007**, (2024), <https://doi.org/10.1063/5.0218937>
33. M.Jalilov, M.Azimova, A.Jalilova. *On a new technology of preparation of hot drinking water*. Energetika Proceedings of Cis Higher Education Institutions and Power Engineering Associations, **60(5)**, (2017), pp.484-492. <https://doi.org/10.21122/1029-7448-2017-60-5-484-492>
34. S.Amirov, A.Sulliev, U.Mukhtorov. *Resonance sensors of motion parameters*. AIP Conference Proceedings, 3256(1), 050028, (2025). <https://doi.org/10.1063/5.0267548>
35. K.Turdibekov, A.Sulliev, O.Iskandarova, J.Boqulov. *Experimental and statistical methods for studying the modes of electric power systems under conditions of uncertainty*. E3S Web of Conferences, 452, **04002**, (2023), <https://doi.org/10.1051/e3sconf/202345204002>
36. S.Kasimov, A.Sulliev, A.Eshkabilov. *Optimising Pulse Combustion Systems for Enhanced Efficiency and Sustainability in Thermal Power Engineering*. E3S Web of Conferences, 449, **06006**, (2023), <https://doi.org/10.1051/e3sconf/202344906006>
37. S.Amirov, A.Sulliev, S.Sharapov. *Study on differential transformer displacement sensors*. E3S Web of Conferences, 434, **02011**, (2023), <https://doi.org/10.1051/e3sconf/202343402011>
38. S.Amirov, A.Sulliev, K.Turdibekov. *Investigation of biparametric resonance sensors with distributed parameters*. E3S Web of Conferences, 377, **01002**, (2023), <https://doi.org/10.1051/e3sconf/202337701002>
39. M.Yakubov, A.Sulliev, A.Sanbetova. *Modern methods of evaluation of metrological indicators of channels for measurement and processing of diagnostic values of traction power supply*. IOP Conference Series Earth and Environmental Science, 1142(1), **012010**, (2023), [doi:10.1088/1755-1315/1142/1/012010](https://doi.org/10.1088/1755-1315/1142/1/012010)
40. K.Turdibekov, A.Sulliev, I.Qurbanov, S.Samatov, A.Sanbetova. *Voltage Symmetration in High Speed Transport Power Supply Systems*. AIP Conference Proceedings, 2432, **030084**, (2022), <https://doi.org/10.1063/5.0089958>

41. K.Turdibekov, M.Yakubov, A.Sulliev. *Mathematical Models of Asymmetric Modes in High-Speed Traffic*. Lecture Notes in Networks and Systems, **247**, (2022), pp.1051-1058. [DOI:10.1007/978-3-030-80946-1_95](https://doi.org/10.1007/978-3-030-80946-1_95)
42. S.K.Shah, L.Safarov, A.Sanbetova, and etc. *Investigation on composite phase change materials for energy-saving buildings*. E3S Web of Conferences, 563, **01003**, (2024), <https://doi.org/10.1051/e3sconf/202456301003>
43. A.Sanbetova, A.Mukhammadiev, A.Rakhmatov, Z.Beknazarova. *Study on cultivation of environmentally friendly seed potatoes based on electrical technology*. E3S Web of Conferences, 377, **03001**, (2023), <https://doi.org/10.1051/e3sconf/202337703001>
44. J.Safarov, A.Khujakulov, Sh.Sultanova, U.Khujakulov, S.Verma. *Research on energy efficient kinetics of drying raw material*. E3S Web of Conferences, 216, **01093**, (2020). <https://doi.org/10.1051/e3sconf/202021601093>
45. J.Safarov, Sh.Sultanova, G.Dadayev, Sh.Zulponov. *Influence of the structure of coolant flows on the temperature profile by phases in a water heating dryer*. IOP Conf. Series: Materials Science and Engineering, 1029(1), **012019**, (2021). [doi:10.1088/1757-899X/1029/1/012019](https://doi.org/10.1088/1757-899X/1029/1/012019)
46. Sh.Sultanova, A.Artikov, Z.Masharipova, A.Tarawade, J.Safarov. *Results of experiments conducted in a helio water heating convective drying plant*. IOP Conf. Series: Earth and Environmental Science, 868(1), **012045**, (2021). [doi:10.1088/1755-1315/868/1/012045](https://doi.org/10.1088/1755-1315/868/1/012045)
47. Sh.Sultanova, J.Safarov, A.Usenov, D.Samandarov, T.Azimov. *Ultrasonic extraction and determination of flavonoids*. AIP Conference Proceedings, 2507, **050005**, (2023). <https://doi.org/10.1063/5.0110524>
48. Dj.Saparov, S.Sultonova, E.Guven, D.Samandarov, A.Rakhimov. *Theoretical study of characteristics and mathematical model of convective drying of foods*. E3S Web of Conferences, 461, **01057**, (2023). <https://doi.org/10.1051/e3sconf/202346101057>
49. Sh.Sultanova, J.Safarov, A.Usenov, T.Raxmanova. *Definitions of useful energy and temperature at the outlet of solar collectors*. E3S Web of Conferences, 216, **01094**, (2020). <https://doi.org/10.1051/e3sconf/202021601094>
50. Sh.Zulpanov, D.Samandarov, G.Dadayev, S.Sultonova, J.Safarov. *Research of the influence of mulberry silkworm cocoon structure on drying kinetics*. IOP Conf. Series: Earth and Environmental Science, 1076, **012059**, (2022). [doi:10.1088/1755-1315/1076/1/012059](https://doi.org/10.1088/1755-1315/1076/1/012059)
51. A.Tarawade, D.Samandarov, T.Azimov, Sh.Sultanova, J.Safarov. *Theoretical and experimental study of the drying process of mulberry fruits by infrared radiation*. IOP Conf. Series: Earth and Environmental Science, 1112, **012098**, (2022). [doi:10.1088/1755-1315/1112/1/012098](https://doi.org/10.1088/1755-1315/1112/1/012098)
52. M.Mirsadov, B.Fayzullayev, I.Abdullabekov, A.Kupriyanova, D.Kurbanbayeva, U.Boqijonov. *The mutual influence of electromagnetic and mechanical processes in dynamic modes of inertial vibrating electric drives*. IOP Conference Series Materials Science and Engineering, 862(6), **062081**, (2020). [doi:10.1088/1757-899X/862/6/062081](https://doi.org/10.1088/1757-899X/862/6/062081)
53. I.Abdullabekov, M.Mirsaidov, F.Tuychiev, R.Dusmatov. *Frequency converter – asynchronous motor – pump pressure piping system mechanical specifications*. AIP Conference Proceedings, 3152, **040007** (2024). <https://doi.org/10.1063/5.0218880>
54. I.Abdullabekov, M.Mirsaidov, Sh.Umarov, M.Tulyaganov, S.Oripov. *Optimizing energy efficiency in water pumping stations: A case study of the Chilonzor water distribution facility*. AIP Conference Proceedings, 3331, **030107**, (2025). <https://doi.org/10.1063/5.0305780>
55. M.Bobojanov, F.Tuychiev, N.Rashidov, A.Haqberdiyev, I.Abdullabekov. *Dynamic simulation of a three-phase induction motor using Matlab Simulink*. AIP Conference Proceedings, 3331, **040012**, (2025). <https://doi.org/10.1063/5.0305750>
56. M.Tulyaganov, Sh.Umarov, I.Abdullabekov, Sh.Adilova. *Optimization of modes of an asynchronous electric drive taken into account thermal transient processes*. AIP Conference Proceedings, 3331, **030084**, (2025). <https://doi.org/10.1063/5.0305786>
57. Sh.Umarov, Kh.Sapaev, I.Abdullabekov. *The Implicit Formulas of Numerical Integration Digital Models of Nonlinear Transformers*. AIP Conference Proceedings, 3331, **030105**, (2025), <https://doi.org/10.1063/5.0305793>
58. G.Boboyev, N.Inatova. *The Importance of Implementing Energy Management Systems for Manufacturing Enterprises in the Republic of Uzbekistan*. AIP Conference Proceedings, 3331(1), **040047**, (2025). <https://doi.org/10.1063/5.0305865>
59. A.T.Rakhmanov, G.G.Boboiev. *Developing the Technology for Manufacturing Ohmic Contacts and Sealing Semiconductor Temperature Converters*. Journal of Engineering Physics and Thermophysics, 98(3), (2025), pp.841-845. <https://doi.org/10.1007/s10891-025-03163-6>
60. G.Boboyev, N.Nurmukhamedov, O.Zaripov. *Improvement of Means of Measuring the Main Parameters of Electricity*. AIP Conference Proceedings, 3331(1), **040039**, (2025). <https://doi.org/10.1063/5.0305861>

61. N.I.Avezova, P.R.Ismatullayev, P.M.Matyakubova, G.G Boboyev. *Multifunctional Heat Converter Moisture Content of Liquid Materials*. International Conference on Information Science and Communications Technologies Applications Trends and Opportunities Iciscet 2019, 9012041, (2019). DOI: [10.1109/ICISCT47635.2019.9012041](https://doi.org/10.1109/ICISCT47635.2019.9012041)
62. Sh.Kuchkanov, M.Adilov, B.Abduraxmanov, A.Kamardin, S.Maksimov, S.Nimatov, and Kh.Ashurov. *Thermovoltaic effect in Si/Si epitaxial film structures treated by neon ions*. AIP Conference Proceedings, **3331**, **040045**, (2025). <https://doi.org/10.1063/5.0305887>
63. M.Atajonov, Q.Mamarasulov, O.Zaripov, S.Nimatov, U.Bo'riyev. *Study of Solar Photoelectric Plant in Matlab (Simulink) Package*. AIP Conference Proceedings, 3244(1), **060001**, (2024). <https://doi.org/10.1063/5.0241783>
64. S.J.Nimatov, D.S.Rumi. *Investigation of the dose dependence of the amorphization of a Si(111) surface bombarded with low-energy Na⁺ ions*. Journal of Surface Investigation, 8(2), (2014), pp.404-407. DOI: [10.1134/S1027451014020396](https://doi.org/10.1134/S1027451014020396)
65. S.J.Nimatov, D.S.Rumi. *Submonolayer films on a Si(111) surface under low-energy ion bombardment*. Bulletin of the Russian Academy of Sciences Physics, 78(6), (2014), pp.531-534. DOI: [10.3103/S1062873814060215](https://doi.org/10.3103/S1062873814060215)
66. S.J.Nimatov, I.A.Garafutdinova, B.G Atabaev, D.S.Rumi. *Low energy electron diffraction investigation of the defect formation in the electron-beam stimulated solid phase epitaxy of Ge on Si(111)*. Surface Investigation X Ray Synchrotron and Neutron Techniques, 16(5), (2001), pp.775-779.
67. D.S.Rumi, S.Zh.Nimatov, I.A.Garafutdinova, B.G.Atabaev, S.V.Shevelev. *The investigation of the structure and anisotropy of emission characteristics of (111) zone of a cylindrical tungsten single crystal*. Surface Investigation X Ray Synchrotron and Neutron Techniques, 16(6), (2001), pp.941-948.
68. A.Udaratin, A.Alyunov, A.Krutikov, L.R.Mukhametova, O.O.Zaripov, I.V.Bochkarev. *Efficiency study of the reactive shunt compensation device in power lines*. E3S Web of Conferences, 124, **02020**, (2019), <https://doi.org/10.1051/e3sconf/201912402020>
69. P.M.Matyakubova, P.R.Ismatullaev, N.I.Avezova, M.M.Makhmudzhonov. *Block Diagram of APCS of Installations for Wet-Heat Processing of Grain Products*. Journal of Engineering Physics and Thermophysics, 96(6), (2023), pp.1652-1657. DOI: [10.1007/s10891-023-02835-5](https://doi.org/10.1007/s10891-023-02835-5)
70. S.M.Turabdzhanov, J.M.Tangirov, P.M.Matyakubova, N.S.Amirkhulov, S.S.Khabibullaev. *Methods of providing metrological supply when pumping water into wells in oil fields*. AIP Conference Proceedings, 3045(1), **030073**, (2024), <https://doi.org/10.1063/5.0197355>
71. P.Matyakubova, P.Ismatullaev, J.Shamuratov. *Development of vibration viscometer for industry purpose and experience of its practical*. E3S Web of Conferences, 365, **05012**, (2023), <https://doi.org/10.1051/e3sconf/202336505012>
72. N.I.Avezova, P.M.Matyakubova, P.R.Ismatullaev, S.A.Kodirova. *Design and Practical Application of Thermal Humidity Converters for Liquid Materials*. Journal of Engineering Physics and Thermophysics, 96(1), (2023), pp.206-214. DOI: [10.1007/s10891-023-02677-1](https://doi.org/10.1007/s10891-023-02677-1)
73. N.I.Avezova, P.R.Ismatullaev, P.M.Matyakubova, Sh.A.Kodirova. *Mathematical model of a heat transducer with a cylindrical heat pipeline and with a focused heat source*. Journal of Physics Conference Series, 1686(1), **012063**, (2020), DOI: [10.1088/1742-6596/1686/1/012063](https://doi.org/10.1088/1742-6596/1686/1/012063)
74. O.Khakimov, P.M.Matyakubova, G.A.Gaziev, R.R.Jabbarov. *Evaluation of ultrasound reflection coefficient measurement result and its uncertainty by the method of linearization*. Proceedings of the International Conference on Advanced Optoelectronics and Lasers Caol, 9019476, (2019), pp.721-723, DOI: [10.1109/CAOL46282.2019.9019476](https://doi.org/10.1109/CAOL46282.2019.9019476)